



September 6, 2019

**Mr. Josh Warriner**  
Operations  
Pepper Construction Company  
411 Lake Zurich Road  
Barrington, IL 60010

E-mail: JWarriner@pepperconstruction.com

**RE: DRINKING WATER SAMPLING REPORT AND RESULTS  
COVENTRY ELEMENTARY SCHOOL**

Dear Mr. Warriner:

Pepper Environmental is pleased to provide you with the results of the water testing performed on August 30, 2019 at Coventry Elementary School in Crystal Lake, Illinois.

On August 30, 2019 a first draw water samples were collected from two (2) water sources in various locations throughout the above referenced school. A first draw water samples is a 1 liter sample of tap water that has stood motionless in the plumbing pipes for at least 6 hours and is collected without flushing the tap (40 CFR 141.2). All tap water samples that were collected were first draw samples for lead and collected in accordance with 40 CFR 141.86(b)(2). The water samples were then taken and analyzed at STAT Analysis Corporation in Chicago; for the presence of lead. Sampling locations and the lab results are attached.

**All samples collected were below the EPA recommended action level of 15 ppb. No further testing will be required.**

If you have any questions please call me at 847.304.1326. Please sign the authorization line below if you agree with this proposal.

Sincerely,  
Pepper Environmental Technologies, Inc.

A handwritten signature in black ink, appearing to read "Vlastimil Korec", written over a horizontal line.

Vlastimil Korec – Project Engineer

**FLUSH FOLLOW UP WATER SAMPLING LOCATIONS AND RESULTS**

<b>Sample Number &amp; Location</b>	<b>First Draw Water Sampling Result (parts per billion)</b>	<b>Result After Flush (parts per billion)</b>
<b>COVENTRY ELEMENTARY SCHOOL</b>		
1. East Fountain	<2.0	<2.0
2. West Fountain	<2.0	<2.0